

Hillcreek Service Call Tracking

House/ Apartment #	Street Name	Date	Failure Type
7731	Hillcreek	1/19/2021	pipng inside tank
701	Covered Bridge	1/22/2021	repaired wiring
7150	Chimney Ridge	1/22/2021	pipng inside tank
7650	Cave Creek	1/24/2021	replaced pump
7600	Cave Creek	2/1/2021	repaired float
275	High Point Ln	2/1/2021	repaired float
275	High Point Ln	2/2/2021	repaired control cable
7701	Chimney Ridge	2/16/2021	repaired float
7600	Cave Creek	2/17/2021	replaced pump
950	Covered Bridge	2/19/2021	reset pump
950	Covered Bridge	2/20/2021	replaced pump
950	Covered Bridge	2/20/2021	repaired float
7731	Hillcreek	2/23/2021	repaired float
620	Logwood	3/1/2021	repaired float
950	Covered Bridge	3/1/2021	pump tripped
950	Covered Bridge	3/1/2021	pump tripped
8151	Hillcreek	3/9/2021	replaced pump
950	Covered Bridge	3/9/2021	repaired internal piping
547	High Point Ln	3/10/2021	repaired float
7600	Cave Creek	3/20/2021	working properly when arrived
7451	Chimney Ridge	4/11/2021	curcuit board replaced
7501	Covered Bridge	4/11/2021	reset pump
7600	Cave Creek	4/23/2021	replaced float
7701	Chimney Ridge	4/23/2021	repaired float
601	Covered Bridge	5/1/2021	replaced float
601	Covered Bridge	5/8/2021	reset floats
601	Logwood	5/11/2021	reset pump