

**Boone County Regional Sewer District
Operations and Maintenance Report
Virgil Farnen
August 10th, 2021**

Hillcreek – Cleaned and inspected Air/Vacuum Release valves. Replaced one A/V valve and one shut-off valve.

Rockbridge Estates – Took apart a manhole and replaced mastic at joints. Injected a epoxy sealant around the A-Lock gaskets.

Line Maintenance – 14910 ft of routine maintenance completed, 366 ft of cctv

Pump Maintenance – Newtown, and Rocheport.

DNR Inspection – No Inspections

Pressure Service Calls - Hillcreek – 6 Woodlands – 4 Deerfield – 1
Brookfield – 2 Lake Capri – 2 Richardson – 1
Sheridan - 1

MO One Calls – Received 267, Located 78

Ongoing and Planned Activities – Right of Way inspection and maintenance. Septic tank pumping at Woodlands, Quarter Mile, Brookfield and Brown. South Rt. K, berm and ditch repair. Sturgeon lift station evaluations.

Shalimar Lift Station Upgrade – Attempted Start-up, Guide Rail systems did not match new pumps.

Hwy 40 & J – Plowing in of drip irrigation tubing has started.

Connection Inspections – Total inspections - 17, Gravity – 10, Pressure – 7,
Final Inspections - 4