

Hillcreek Service Call Tracking

House/ Apartment #	Street Name	Date	Failure Type	Labor Hrs
7731	Hillcreek	1/19/2021	pipng inside tank	
701	Covered Bridge	1/22/2021	repaired wiring	
7150	Chimney Ridge	1/22/2021	pipng inside tank	
7650	Cave Creek	1/24/2021	replaced pump	
7600	Cave Creek	2/1/2021	repaired float	
275	High Point Ln	2/1/2021	repaired float	
275	High Point Ln	2/2/2021	repaired control cable	
7701	Chimney Ridge	2/16/2021	repaired float	
7600	Cave Creek	2/17/2021	replaced pump	
950	Covered Bridge	2/19/2021	reset pump	
950	Covered Bridge	2/20/2021	replaced pump	
950	Covered Bridge	2/20/2021	repaired float	
7731	Hillcreek	2/23/2021	repaired float	
620	Logwood	3/1/2021	repaired float	
950	Covered Bridge	3/1/2021	pump tripped	
950	Covered Bridge	3/1/2021	pump tripped	
8151	Hillcreek	3/9/2021	replaced pump	
950	Covered Bridge	3/9/2021	repaired internal piping	
547	High Point Ln	3/10/2021	repaired float	
7600	Cave Creek	3/20/2021	working properly when arrived	
7451	Chimney Ridge	4/11/2021	curcuit board replaced	
7501	Covered Bridge	4/11/2021	reset pump	
7600	Cave Creek	4/23/2021	replaced float	
7701	Chimney Ridge	4/23/2021	repaired float	
601	Covered Bridge	5/1/2021	replaced float	
601	Covered Bridge	5/8/2021	reset floats	
601	Logwood	5/11/2021	reset pump	
7450	Chimney Ridge	6/7/2021	repaired float	
950	Covered Bridge	6/16/2021	grease buildup	
950	Covered Bridge	6/19/2021	replaced pump	

Hillcreek Service Call Tracking

House/ Apartment #	Street Name	Date	Failure Type	Labor Hrs
7550	Cave Creek	6/30/2021	grease buildup	
7500	Cave Creek	6/30/2021	repaired float	
7550	Cave Creek	7/2/2021	grease buildup	
7550	Cave Creek	7/3/2021	reset pump	
7550	Cave Creek	7/5/2021	replaced pump	
950	Covered Bridge	7/14/2021	reset pump	
720	Logwood	7/22/2021	replaced float	
7701	Chimney Ridge	7/30/2021	replaced all floats and cable	

