

**Boone County Regional Sewer District
Operations and Maintenance Report
Virgil Farnen
September 9, 2021**

Septic Tank Servicing – Brookfield, Quarter Mile and Woodlands.

City of Sturgeon – Evaluated the needs of 4 lift stations, and determined spare parts on hand. Developed cost for needed maintenance. Council recently approved those expenses.

Hillview – Completed 2 main line repairs.

South Route K – Ditch clearing, brush disposal and lagoon berm repair.

Pump Maintenance – Bonne Femme, Hartsburg and Rocheport.

DNR Inspection – No Inspections

Pressure Service Calls - Hillcreek – 6 Woodlands – 2 Deerfield – 1
Brookfield – 3 Lake Capri – 1 Kinkade – 2
County Downes - 2

MO One Calls – Received 333, Located 134

Ongoing and Planned Activities – Right of Way inspection and maintenance. Septic tank pumping at Woodlands and Brown Station. Filter cleaning at Fall Creek and Deerfield. Right of Way Maintenance.

Shalimar Lift Station Upgrade – Construction near completion. Fence to be built. Cellular antenna to be installed. Gravel turn around to be constructed.

Hwy 40 & J – Tanks have been set and plumbed. Building foundation poured. Distribution piping under construction.

Connection Inspections – Total inspections - 10, Gravity – 9, Pressure – 1,
Final Inspections - 1