

October, 2021

November 23, 2020	Sunnyslope	Unsatisfactory Finding	Failed to submit I&I reports Exceeded effluent Limits	Response Provided by email	No Further Action Requi
March 5, 2021	Cedar Gate	Letter of Warning	Failed to Submit Discharge Reports Failed to Submit I&I Reports for 2019	Provided proof reports submitted before due Provided a annual I&I report.	
March 5, 2021 August 16, 2021	Trails West Trails West	Letter of Warning Facility in Compliance	Failed to Submit I&I Report for 2019 DNR wrote that they mistakenly issued a LOW	Provided proof no I&I report was due for 2019	
March 11, 2021	Kinkade Crossing	Unsatisfactory Finding	Failed to record DO level of sludge storage	Emailed that we would start recording DO levels of sludge storage	
June 21, 2021	Highfield Acres	Letter of Warning	Exceeded the Monthly Average Limit for BOD (45 mg/l) DNR sample 53.6 mg/l. Duckweed present in ditch Explained why we thought the exceedence occurred. Installed "Tee's" on discharege pipes.		