

**Boone County Regional Sewer District
Operations and Maintenance Report
Virgil Farnen
December 14, 2021**

HH Corridor – Cleaned, rebuilt, and replaced A/V valves on force main.

Line Maintenance – 13355’ jetted or sawed and 1055’ cctv’d.

Waters Edge – Rebuilt interior piping and installed new pumps on grinder units.

South Route K – Dewatered 31000 gallons of sludge, and hauled 25000 gallons from Prairie Meadows to South Route K to process.

Pump Maintenance – Rocheport and Sturgeon

DNR Inspection – No Inspections. No Letters of Warning or Notices of Violation

Pressure Service Calls - Hillcreek – 5 Woodlands – 6 Deerfield – 2
Brookfield – 1 Lake Capri – 1 Kinkade – 1
Waters Edge – 1 Fall Creek – 1 Heather Hills - 1

MO One Calls – Received 297, Located 71

Ongoing and Planned Activities - Line Maintenance, Sludge Hauling and Processing,

MidwayUSA @ Hwy 40 & J – Completed and receiving flow.

Oak Hill – Main line construction completed. Contractor pressure test and continuity.

Connection Inspections – Total inspections - 29, Gravity – 27, Pressure – 2,
Final Inspections - 5