

## Hillcreek Service Call Tracking

House/ Apartment #	Street Name	Date	Failure Type
7731	Hillcreek	1/19/2021	pipng inside tank
701	Covered Bridge	1/22/2021	repaired wiring
7150	Chimney Ridge	1/22/2021	pipng inside tank
7650	Cave Creek	1/24/2021	replaced pump
7600	Cave Creek	2/1/2021	repaired float
275	High Point Ln	2/1/2021	repaired float
275	High Point Ln	2/2/2021	repaired control cable
7701	Chimney Ridge	2/16/2021	repaired float
7600	Cave Creek	2/17/2021	replaced pump
950	Covered Bridge	2/19/2021	reset pump
950	Covered Bridge	2/20/2021	replaced pump
950	Covered Bridge	2/20/2021	repaired float
7731	Hillcreek	2/23/2021	repaired float
620	Logwood	3/1/2021	repaired float
950	Covered Bridge	3/1/2021	pump tripped
950	Covered Bridge	3/1/2021	pump tripped
8151	Hillcreek	3/9/2021	replaced pump
950	Covered Bridge	3/9/2021	repaired internal piping
547	High Point Ln	3/10/2021	repaired float
7600	Cave Creek	3/20/2021	working properly when arrived
7451	Chimney Ridge	4/11/2021	curcuit board replaced
7501	Covered Bridge	4/11/2021	reset pump
7600	Cave Creek	4/23/2021	replaced float
7701	Chimney Ridge	4/23/2021	repaired float
601	Covered Bridge	5/1/2021	replaced float
601	Covered Bridge	5/8/2021	reset floats
601	Logwood	5/11/2021	reset pump
7450	Chimney Ridge	6/7/2021	repaired float
950	Covered Bridge	6/16/2021	grease buildup
950	Covered Bridge	6/19/2021	replaced pump
7550	Cave Creek	6/30/2021	grease buildup
7500	Cave Creek	6/30/2021	repaired float
7550	Cave Creek	7/2/2021	grease buildup
7550	Cave Creek	7/3/2021	reset pump
7550	Cave Creek	7/5/2021	replaced pump
950	Covered Bridge	7/14/2021	reset pump
720	Logwood	7/22/2021	replaced float
7701	Chimney Ridge	7/30/2021	replaced all floats and cable
7450	Chimney Ridge	8/2/2021	replaced floats
1151	Covered Bridge	8/5/2021	replaced float
7701	Chimney Ridge	8/7/2021	repaired float
8002	Hillcreek	8/11/2021	repaired float
8002	Hillcreek	8/21/2021	pump plugged
7611	Hillcreek	8/22/2021	replaced pump
800	Covered Bridge	9/18/2021	replaced float

## Hillcreek Service Call Tracking

<b>House/ Apartment #</b>	<b>Street Name</b>	<b>Date</b>	<b>Failure Type</b>
8002	Hillcreek	9/19/2021	replaced float
7902	Hillcreek	9/19/2021	replaced pump
7701	Chimney Ridge	10/2/2021	replaced pump
7731	Hillcreek	10/18/2021	replaced pump
620	Logwood Ln	10/25/2021	control panel issue
620	Logwood Ln	10/31/2021	replaced float
751	Covered Bridge	11/4/2021	pipng inside tank
901	Covered Bridge	11/9/2021	control panel issue
751	Covered Bridge	11/19/2021	repaired float
450	Covered Bridge	11/28/2021	control panel issue
7431	Cave Creek	11/29/2021	pump reset