

Hillcreek Service Call Tracking

House/ Apartment #	Street Name	Date	Failure Type	Labor Hrs
7731	Hillcreek	1/19/2021	pipng inside tank	
701	Covered Bridge	1/22/2021	repaired wiring	
7150	Chimney Ridge	1/22/2021	pipng inside tank	
7650	Cave Creek	1/24/2021	replaced pump	
7600	Cave Creek	2/1/2021	repaired float	
275	High Point Ln	2/1/2021	repaired float	
275	High Point Ln	2/2/2021	repaired control cable	
7701	Chimney Ridge	2/16/2021	repaired float	
7600	Cave Creek	2/17/2021	replaced pump	
950	Covered Bridge	2/19/2021	reset pump	
950	Covered Bridge	2/20/2021	replaced pump	
950	Covered Bridge	2/20/2021	repaired float	
7731	Hillcreek	2/23/2021	repaired float	
620	Logwood	3/1/2021	repaired float	
950	Covered Bridge	3/1/2021	pump tripped	
950	Covered Bridge	3/1/2021	pump tripped	
8151	Hillcreek	3/9/2021	replaced pump	
950	Covered Bridge	3/9/2021	repaired internal piping	
547	High Point Ln	3/10/2021	repaired float	
7600	Cave Creek	3/20/2021	working properly when arrived	
7451	Chimney Ridge	4/11/2021	curcuit board replaced	
7501	Covered Bridge	4/11/2021	reset pump	
7600	Cave Creek	4/23/2021	replaced float	
7701	Chimney Ridge	4/23/2021	repaired float	
601	Covered Bridge	5/1/2021	replaced float	
601	Covered Bridge	5/8/2021	reset floats	
601	Logwood	5/11/2021	reset pump	
7450	Chimney Ridge	6/7/2021	repaired float	
950	Covered Bridge	6/16/2021	grease buildup	
950	Covered Bridge	6/19/2021	replaced pump	

Hillcreek Service Call Tracking

House/ Apartment #	Street Name	Date	Failure Type	Labor Hrs
7550	Cave Creek	6/30/2021	grease buildup	
7500	Cave Creek	6/30/2021	repaired float	
7550	Cave Creek	7/2/2021	grease buildup	
7550	Cave Creek	7/3/2021	reset pump	
7550	Cave Creek	7/5/2021	replaced pump	
950	Covered Bridge	7/14/2021	reset pump	
720	Logwood	7/22/2021	replaced float	
7701	Chimney Ridge	7/30/2021	replaced all floats and cable	
7450	Chimney Ridge	8/2/2021	replaced floats	
1151	Covered Bridge	8/5/2021	replaced float	
7701	Chimney Ridge	8/7/2021	repaired float	
8002	Hillcreek	8/11/2021	repaired float	
8002	Hillcreek	8/21/2021	pump plugged	
7611	Hillcreek	8/22/2021	replaced pump	
800	Covered Bridge	9/18/2021	replaced float	
8002	Hillcreek	9/19/2021	replaced float	
7902	Hillcreek	9/19/2021	replaced pump	
7701	Chimney Ridge	10/2/2021	replaced pump	
7731	Hillcreek	10/18/2021	replaced pump	
620	Logwood Ln	10/25/2021	control panel issue	
620	Logwood Ln	10/31/2021	replaced float	
751	Covered Bridge	11/4/2021	pipng inside tank	
901	Covered Bridge	11/9/2021	control panel issue	
751	Covered Bridge	11/19/2021	repaired float	
450	Covered Bridge	11/28/2021	control panel issue	
7431	Cave Creek	11/29/2021	pump reset	
670	Logwood Ln	12/6/2021	repair float	
450	Covered Bridge	12/12/2021	pump reset	
7150	Chimney Ridge	12/15/2021	replaced pump	
450	Covered Bridge	12/15/2021	pump reset	

Hillcreek Service Call Tracking

House/ Apartment #	Street Name	Date	Failure Type	Labor Hrs
450	Covered Bridge	12/21/2021	replaced pump	
7852	Hillcreek	12/21/2021	private problem	
1191	Covered Bridge	12/30/2021	repair float	