

Hillcreek Service Call Tracking

| Street Name | Date | Failure Type |
|----------------|-----------|-------------------------------|
| Hillcreek | 1/19/2021 | pipng inside tank |
| Covered Bridge | 1/22/2021 | repaired wiring |
| Chimney Ridge | 1/22/2021 | pipng inside tank |
| Cave Creek | 1/24/2021 | replaced pump |
| Cave Creek | 2/1/2021 | repaired float |
| High Point Ln | 2/1/2021 | repaired float |
| High Point Ln | 2/2/2021 | repaired control cable |
| Chimney Ridge | 2/16/2021 | repaired float |
| Cave Creek | 2/17/2021 | replaced pump |
| Covered Bridge | 2/19/2021 | reset pump |
| Covered Bridge | 2/20/2021 | replaced pump |
| Covered Bridge | 2/20/2021 | repaired float |
| Hillcreek | 2/23/2021 | repaired float |
| Logwood | 3/1/2021 | repaired float |
| Covered Bridge | 3/1/2021 | pump tripped |
| Covered Bridge | 3/1/2021 | pump tripped |
| Hillcreek | 3/9/2021 | replaced pump |
| Covered Bridge | 3/9/2021 | repaired internal piping |
| High Point Ln | 3/10/2021 | repaired float |
| Cave Creek | 3/20/2021 | working properly when arrived |
| Chimney Ridge | 4/11/2021 | curcuit board replaced |
| Covered Bridge | 4/11/2021 | reset pump |
| Cave Creek | 4/23/2021 | replaced float |
| Chimney Ridge | 4/23/2021 | repaired float |
| Covered Bridge | 5/1/2021 | replaced float |
| Covered Bridge | 5/8/2021 | reset floats |
| Logwood | 5/11/2021 | reset pump |
| Chimney Ridge | 6/7/2021 | repaired float |
| Covered Bridge | 6/16/2021 | grease buildup |
| Covered Bridge | 6/19/2021 | replaced pump |
| Cave Creek | 6/30/2021 | grease buildup |
| Cave Creek | 6/30/2021 | repaired float |
| Cave Creek | 7/2/2021 | grease buildup |
| Cave Creek | 7/3/2021 | reset pump |
| Cave Creek | 7/5/2021 | replaced pump |
| Covered Bridge | 7/14/2021 | reset pump |
| Logwood | 7/22/2021 | replaced float |
| Chimney Ridge | 7/30/2021 | replaced all floats and cable |
| Chimney Ridge | 8/2/2021 | replaced floats |
| Covered Bridge | 8/5/2021 | replaced float |
| Chimney Ridge | 8/7/2021 | repaired float |
| Hillcreek | 8/11/2021 | repaired float |
| Hillcreek | 8/21/2021 | pump plugged |
| Hillcreek | 8/22/2021 | replaced pump |

Hillcreek Service Call Tracking

| Street Name | Date | Failure Type |
|----------------|------------|---------------------|
| Covered Bridge | 9/18/2021 | replaced float |
| Hillcreek | 9/19/2021 | replaced float |
| Hillcreek | 9/19/2021 | replaced pump |
| Chimney Ridge | 10/2/2021 | replaced pump |
| Hillcreek | 10/18/2021 | replaced pump |
| Logwood Ln | 10/25/2021 | control panel issue |
| Logwood Ln | 10/31/2021 | replaced float |
| Covered Bridge | 11/4/2021 | pipng inside tank |
| Covered Bridge | 11/9/2021 | control panel issue |
| Covered Bridge | 11/19/2021 | repaired float |
| Covered Bridge | 11/28/2021 | control panel issue |
| Cave Creek | 11/29/2021 | pump reset |
| Logwood Ln | 12/6/2021 | repair float |
| Covered Bridge | 12/12/2021 | pump reset |
| Chimney Ridge | 12/15/2021 | replaced pump |
| Covered Bridge | 12/15/2021 | pump reset |
| Covered Bridge | 12/21/2021 | replaced pump |
| Hillcreek | 12/21/2021 | private problem |
| Covered Bridge | 12/30/2021 | repair float |
| Hillcreek | 1/26/2022 | pump reset |