

**Boone County Regional Sewer District
Operations and Maintenance Report**

Virgil Farnen

March 8, 2022

Line Maintenance – 20045' jetted or sawed and 820' cctv'd.

Pump Maintenance – Rocheport, Concord, Renick and Sturgeon 5X

DNR Inspection – No Inspections. No Letters of Warning or Notices of Violation
DNR set up composite samplers at Rocky Fork, Rocheport,
Midway Crossings and Prairie Meadows. Results from samples
not expected for a few weeks.

Nursery Heights Force Main – An improper water main and sewer main crossing
was discovered by PWSD #1. The District main did not have the proper vertical
clearance with the water main. Emery Sapp & Son's agreed to make the repair,
even though their warranty had expired. District & PWSD # 1 forces assisted and
inspected.

Pressure Service Calls - Hillcreek – 3 Woodlands – 3
Brookfield – 2 Richardson Acres - 1
Kinkade – 2

Gravity Service Calls - 2 Private Problem, 2 Public Stoppages, no claims of
damage.

Contract Service Calls – 3 at Hallsville, 1 at Renick, 5 at Sturgeon

Training – Virgil attended 1 – 4 hour on-line training courses towards license
renewal. Focused on safety.

MO One Calls – Received 280, Located 105

Sturgeon – Applied for permit renewal in Dec. Just received Draft permit, will soon submit comments.

Connection Inspections – Total inspections - 4, Gravity – 0, Pressure – 4,
Final Inspections – 1

Sludge – Dewatered 133000 gallons at Rocky Fork. Hauled 60 tons of dewatered sludge to landfill. That equates to about 7 dry tons of sludge.

On Going and Planned Activities – Sludge hauling and processing, Line maintenance and repairs. Operators are preparing UV systems for the disinfection season.