

**Boone County Regional Sewer District
Operations and Maintenance Report**

Virgil Farnen

July 12, 2022

Line Maintenance – 395ft CCTV completed

Pump Maintenance – Renick, Sturgeon and El Rey

DNR Inspection Reports – No inspections

Pressure Service Calls - Hillcreek – 1 Woodlands – 1
Rocky Fork – 1 Heather Hills - 1
Richardson - 1

Gravity Service Calls - 6 Private Problems, 0 Public Stoppages

Contract Service Calls – 1 at Sturgeon and 3 at Renick

MO One Calls – Received 275, Located 75

Sludge – Dewatered 56000 gallons of sludge at South Route K and Rocky Fork
Hauled 27500 gallons from Midway Arms, Prairie Meadows and
Rollingwood

On Going and Planned Activities – Sludge hauling and processing. Right of Way
Maintenance will get underway. Line Maintenance activities.

Contract Operations;

Sturgeon – Emergency bypass has ceased. Farmer initiated irrigation.

Aerial crossing replaced. A second pump was approved and order for the South lift station.

Ashland – Solids management continues to be a priority.

Two air supply lines had to be repaired. Water levels had to be lowered in 2 basins to complete repairs.

AeroMod was onsite for a day for training and assistance on troubleshooting. Programming changes were made to get the system back to a normal operating sequence. District sent 2 additional operators to attend.

Multiple neglected maintenance requirements are being addressed.