

Hillcreek Service Call Tracking

House/ Apartment #	Street Name	Date	Failure Type
7415	Hillcreek	1/26/2022	pump reset
851	Covered Bridge	2/6/2022	pump reset
701	Covered Bridge	2/10/2022	repair float
7452	Hillcreek	2/16/2022	replace pump
8151	Hillcreek	3/7/2022	repair float
7350	Chimney Ridge	3/20/2022	replaced control cable
7800	Cave Creek	3/21/2022	repair service line
7600	Cave Creek	4/8/2022	repair service line
7650	Cave Creek	4/12/2022	cleaned floats
1171	Covered Bridge	4/17/2022	repaired float
651	Ridge Run	4/19/2022	replaced fuse and cleaned
651	Ridge Run	4/23/2022	replaced pump
7601	Cave Creek	5/19/2022	replaced 3 float switches
7450	Chimney Ridge	5/22/2022	pump reset
751	Covered Bridge	5/24/2022	replace pump
651	Covered Bridge	5/25/2022	replace float switch
263	High Point Ln	5/28/2022	replace float switch
8021	Hillcreek	5/30/2022	replaced pump
851	Covered Bridge	5/31/2022	pump reset
7601	Cave Creek	6/22/2022	repaired float switch