

**Boone County Regional Sewer District  
Operations and Maintenance Report**

**Virgil Farnen  
August 8, 2022**

**Line Maintenance** – 4210ft Root sawed or jetted (3-Month List)

**Pump Maintenance** – 2 pumps at Sturgeon

**DNR Inspection Reports** – No inspections

**Pressure Service Calls - 21**

Hillcreek – 9	Woodlands – 5
Rocky Fork – 1	Kinkade – 3
Richardson – 1	Lake Capri – 1
Brookfield – 1	

**Gravity Service Calls -** 11 Private Problems, 0 Public Stoppages

**Contract Service Calls** – 2 at Sturgeon

**MO One Calls** – Received 259, Located 108

**Sludge** – Dewatered 68250 gallons of sludge Rocky Fork.

Hauled 35500 gallons from Rollingwood and Rocky Fork

Hauled 4 Dry tons of sludge to landfill from South Rt K and Rocky Fork

**Inspections** – 19 Total inspections, to include 3 final inspections.

**On Going and Planned Activities** – Sludge hauling and processing. Septic Tank pumping is on schedule. Right of Way maintenance will begin.

**New Construction** – 50ft 8” gravity main at Ravenwood  
550 ft of 2” Force main at Meadow Village

**Contract Operations;**

**Sturgeon** – 2 Service Calls, pumps clogged with debris. Waiting for new pump for South lift station.

**Ashland** – BOD5 Exceedance for July 2022

Solids management continues to be a priority.

Scheduled cleaning of 4 lift stations. Optional task included in contract for additional fees.

Operator has been focusing on preventative maintenance at lift stations

**Renick** – Started operation contract, with focus on getting the irrigation system operating.

**Hartsburg** – Nothing to report