

**Boone County Regional Sewer District
Operations and Maintenance Report**

**Virgil Farnen
October, 2022**

Sewer Jet – Took delivery of new jet and operations crew received training. Further training will take place when schedules allow.

Fleet – A 2023 Ford F250 pickup order has been submitted. \$ 45486.00
Will have to wait on order confirmation and estimated delivery date.

Line Maintenance – 2 Pressure service lines repaired, at Hillcreek and Richardson Acres.

Pump Maintenance – Pulled and cleared pumps at Rocheport and El Rey.
Cleared pump at Sturgeon and Hartsburg.

DNR Inspection Reports – No inspections.

Pressure Service Calls - 10	Hillcreek – 4	Quarter Mile – 2
	Kinkade – 1	County Downes - 1
	Brookfield – 1	Richardson Acres - 1

Gravity Service Calls - 2, All private problems

Contract Service Calls – 1 each at Sturgeon, Ashland and Hartsburg

MO One Calls – Received 274, Located 86

Sludge – Dewatered 42000 gallons of sludge Rocky Fork and South Rte K.
Hauled 5 Dry tons of sludge to landfill from Rocky Fork and South Rte K.

Inspections – 18 total inspections, no final inspections

On Going and Planned Activities – Line maintenance season will be the focus the next few months.

Training – We have 2 crewman attending training to attain or advance their operator certification.

New Construction – 903' of pressure main at Eagle extension and Butch's Investments. 144' of 8" gravity main at Eagle extension and Sun Valley Est.

Contract Operations;

Sturgeon – 1 Service Call, pumps clogged with debris. Reservoir pumping should end this week.

Ashland – Assisted with a service call with a main line stoppage.

Renick – Irrigation was halted and the system was winterized this past week. Bi-monthly visits to check lift stations through the non-irrigation season begin.

Hartsburg – Pulled pump and removed debris.