

**Boone County Regional Sewer District**  
**Operations and Maintenance Report**  
**Virgil Farnen**  
**November, 2022**

**Prairie Meadows** – Generator Fire, burned all the 12V wiring to include the controls. Waiting on repair or replacement estimates.

**New Employee** – A new Wastewater/Equipment Operator was recently hired to fill vacancy.

**Fleet** – Order placed for F250 pickup. Waiting for confirmation that Ford has accepted the order.

**Line Maintenance** – 2 Pressure service lines repaired, at County Downes and the Woodlands

**Pump Maintenance** – Concorde East and El Rey lift stations  
Cleared pumps at Sturgeon and Hartsburg.

<b>Pressure Service Calls - 14</b>	Hillcreek – 3	Lake Capri – 2
	Kinkade – 1	Woodlands - 2
	Brookfield – 3	Richardson Acres - 2
	Fall Creek - 1	

**Gravity Service Calls - 6,** 2 - Public stoppages 4 - Private problems

**Contract Service Calls** – 3 - Sturgeon, 1 – Ashland, 2 - Hartsburg

**MO One Calls** – Received 225, Located 63

**Sludge** – Hauled 12500 gallons of sludge from Rollingwood and Midway Arms

**Inspections** – 16 total inspections, 2 final inspections

**On Going and Planned Activities** – Line maintenance season will be the focus the next few months.

**New Construction** – Brookfield Estates - Construction at the WWTP continued to progress: (Blower Building floor slab and walls, Plant process piping, tertiary divider, electrical conduit to plant)

Eagle Extension – 20' of 8" Gravity Main and 322' Pressure Main & 1 Manhole

**Contract Operations;**

**Sturgeon** – 3 Service Call, pumps clogged with debris.

**Ashland** – Routine O&M on treatment and lift stations. Assisted with a service call with a main line stoppage.

**Renick** – Bi-monthly visits to check lift stations and reservoir

**Hartsburg** – 2 Service Calls, pumps clogged with debris.