

Hillcreek Service Call Tracking

House/ Apartment #	Street Name	Date	Failure Type	Labor Hrs
7415	Hillcreek	1/26/2022	pump reset	
851	Covered Bridge	2/6/2022	pump reset	
701	Covered Bridge	2/10/2022	repair float	
7452	Hillcreek	2/16/2022	replace pump	
8151	Hillcreek	3/7/2022	repair float	
7350	Chimney Ridge	3/20/2022	replaced control cable	
7800	Cave Creek	3/21/2022	repair service line	
7600	Cave Creek	4/8/2022	repair service line	
7650	Cave Creek	4/12/2022	cleaned floats	
1171	Covered Bridge	4/17/2022	repaired float	
651	Ridge Run	4/19/2022	replaced fuse and cleaned	
651	Ridge Run	4/23/2022	replaced pump	
7601	Cave Creek	5/19/2022	replaced 3 float switches	
7450	Chimney Ridge	5/22/2022	pump reset	
751	Covered Bridge	5/24/2022	replace pump	
651	Covered Bridge	5/25/2022	replace float switch	
263	High Point Ln	5/28/2022	replace float switch	
8021	Hillcreek	5/30/2022	replaced pump	
851	Covered Bridge	5/31/2022	pump reset	
7601	Cave Creek	6/22/2022	repaired float switch	
7601	Cave Creek	7/1/2022	replaced float switch	
7771	Hillcreek	7/4/2022	repaired float switch	
720	Logwood Ln	7/9/2022	replaced pump	
650	Covered Bridge	7/14/2022	replaced pump	
7550	Cave Creek	7/16/2022	unclogged pump	
950	Covered Bridge	7/16/2022	replaced pump	
950	Covered Bridge	7/21/2022	air locked	
950	Covered Bridge	7/23/2022	air locked	
950	Covered Bridge	7/26/2022	air locked	
541	Logwood Ln	7/28/2022	replaced pump	

Hillcreek Service Call Tracking

House/ Apartment #	Street Name	Date	Failure Type	Labor Hrs
500	Covered Bridge	8/1/2022	repair float switch	
497	High Point Ln	8/3/2022	replace starter	
8071	Hillcreek	8/5/2022	replace pump and float	
497	High Point Ln	8/8/2022	repair starter	
7600	Cave Creek	8/12/2022	internal piping repair	
7600	Cave Creek	8/20/2022	reset pump	
7600	Cave Creek	8/21/2022	replaced pump and float	
7451	Chimney Ridge	8/22/2022	external pipe repair	
7600	Cave Creek	8/22/2022	repaired float switch	
497	High Point Ln	8/22/2022	replaced pump	
263	High Point Ln	9/21/2022	replaced pump	
670	Logwood Ln	9/28/2022	repaired float switch	
1301	Covered Bridge	9/30/2022	replaced float switch	
720	Logwood Ln	10/1/2022	replace float switches	
959	Covered Bridge	10/5/2022	reset pump	
7502	Hillcreek	10/13/2022	repaired float switch	
205	High Point Ln	10/29/2022	repaired service line	
7500	Cave Creek	11/12/2022	repaired float switch	
950	Covered Bridge	11/23/2022	reset pump	
7500	Cave Creek	11/26/2022	replaced float switches	

