Boone County Regional Sewer District Operations and Maintenance Report Virgil Farnen December, 2022

Prairie Meadows – Generator Fire, generator deemed unrepairable.

Fleet – Order placed for F250 pickup. Waiting for confirmation that Ford has accepted the order.

Line Maintenance – 1 Pressure service lines repaired.

Control cable replaced at Woodlands

Pump Maintenance – New pump installed at Concorde LS.

Pumps pulled and cleared at Rocheport, Newtown

Green Hills, Spring Park and Sturgeon 3X

Pressure Service Calls - 23 Hillcreek - 8 Lake Capri - 2

Kinkade - 1 Woodlands - 6

Deerfield - 1 County Downes - 2

Clear Creek - 1 Quarter Mile - 1

Browns Station - 1

Gravity Service Calls - 5, 0 - Public stoppages 5 - Private problems

Contract Service Calls – 4 - Sturgeon

MO One Calls – Received 245, Located 46

Sludge – 95000 gallons processed from Rocky Fork and South Route K

Inspections – 4 total inspections, 0 final inspections

On Going and Planned Activities – Line maintenance season will be the focus the next few months. Installing a new control panel at Concorde lift station. Sludge processing and disposal.

New Construction – Brookfield Estates - Construction at the WWTP continues, temporary septic tank installed to accept flow from 11 homes in Oak Hills.

Contract Operations;

Sturgeon – 4 Service Call, pumps clogged with debris. Both pumps failed at South lift station. Set up dri-prime diesel pump on Dec 19th that will remain in operation until pumps repaired.

Ashland – Routine O&M on treatment and lift stations. Issues with belt press have been time consuming, but repairs have been made and catching back up on sludge processing.

Renick – Bi-monthly visits to check lift stations and reservoir

Hartsburg – Bi-weekly visits to check lift station and lagoon.