

Hillcreek Service Call Tracking

House/ Apartment #	Street Name	Date	Failure Type
7415	Hillcreek	1/26/2022	pump reset
851	Covered Bridge	2/6/2022	pump reset
701	Covered Bridge	2/10/2022	repair float
7452	Hillcreek	2/16/2022	replace pump
8151	Hillcreek	3/7/2022	repair float
7350	Chimney Ridge	3/20/2022	replaced control cable
7800	Cave Creek	3/21/2022	repair service line
7600	Cave Creek	4/8/2022	repair service line
7650	Cave Creek	4/12/2022	cleaned floats
1171	Covered Bridge	4/17/2022	repaired float
651	Ridge Run	4/19/2022	replaced fuse and cleaned
651	Ridge Run	4/23/2022	replaced pump
7601	Cave Creek	5/19/2022	replaced 3 float switches
7450	Chimney Ridge	5/22/2022	pump reset
751	Covered Bridge	5/24/2022	replace pump
651	Covered Bridge	5/25/2022	replace float switch
263	High Point Ln	5/28/2022	replace float switch
8021	Hillcreek	5/30/2022	replaced pump
851	Covered Bridge	5/31/2022	pump reset
7601	Cave Creek	6/22/2022	repaired float switch
7601	Cave Creek	7/1/2022	replaced float switch
7771	Hillcreek	7/4/2022	repaired float switch
720	Logwood Ln	7/9/2022	replaced pump
650	Covered Bridge	7/14/2022	replaced pump
7550	Cave Creek	7/16/2022	unclogged pump
950	Covered Bridge	7/16/2022	replaced pump
950	Covered Bridge	7/21/2022	air locked
950	Covered Bridge	7/23/2022	air locked
950	Covered Bridge	7/26/2022	air locked
541	Logwood Ln	7/28/2022	replaced pump
500	Covered Bridge	8/1/2022	repair float switch
497	High Point Ln	8/3/2022	replace starter
8071	Hillcreek	8/5/2022	replace pump and float
497	High Point Ln	8/8/2022	repair starter
7600	Cave Creek	8/12/2022	internal piping repair
7600	Cave Creek	8/20/2022	reset pump
7600	Cave Creek	8/21/2022	replaced pump and float
7451	Chimney Ridge	8/22/2022	external pipe repair
7600	Cave Creek	8/22/2022	repaired float switch
497	High Point Ln	8/22/2022	replaced pump
263	High Point Ln	9/21/2022	replaced pump
670	Logwood Ln	9/28/2022	repaired float switch

Hillcreek Service Call Tracking

House/ Apartment #	Street Name	Date	Failure Type
1301	Covered Bridge	9/30/2022	replaced float switch
720	Logwood Ln	10/1/2022	replace float switches
959	Covered Bridge	10/5/2022	reset pump
7502	Hillcreek	10/13/2022	repaired float switch
205	High Point Ln	10/29/2022	repaired service line
7500	Cave Creek	11/12/2022	repaired float switch
950	Covered Bridge	11/23/2022	reset pump
7500	Cave Creek	11/26/2022	replaced float switches
950	Covered Bridge	12/2/2022	pump air locked
800	Covered Bridge	12/2/2022	replaced float switch
950	Covered Bridge	12/3/2022	pump air locked
800	Covered Bridge	12/3/2022	replaced pump
670	Logwood	12/8/2022	repaired float switch
7500	Cave Creek	12/17/2022	replaced float switch
950	Covered Bridge	12/19/2022	pump air locked
263	High Point Ln	12/24/2022	repaired float switch