

Boone County Regional Sewer District
Operations and Maintenance Report
Virgil Farnen
January, 2023

Prairie Meadows – Generator Fire, MOPERM issued a check for the cost of repair. Generator deemed *unrepairable*. District will have to replace generator and MOPERM will pay the value, less deductible.

DNR Inspections – No NOV’s or LOW’s issued.
Hartsburg facility inspected and sample collected.

Fleet – Order placed for F250 pickup. Waiting for confirmation that Ford has accepted the order.

Line Maintenance – 1 Pressure service lines repaired.
20595’ of main line jetted or root sawed.

Pump Maintenance – Pumps pulled at Newtown, Green Hills and Spring Park
Replaced control panel at Concorde lift station.

Pressure Service Calls - 17	Hillcreek – 6	Lake Capri – 1
	Kinkade – 1	Woodlands - 2
	Heather Hills – 2	County Downes - 1
	Clear Creek – 1	Brookfield - 1
	Richardson - 2	

Gravity Service Calls - 8, 1 - Public stoppages 7 - Private problems

Contract Service Calls – 6 – Sturgeon 1- Ashland

MO One Calls – Received 211, Located 72

Sludge – 7500 gallons hauled from Meadow Village

Connection Inspections – 5 total inspections, 1 final inspections

On Going and Planned Activities – Line maintenance season will be the focus the next few months. Sludge processing and disposal.

New Construction – Brookfield Estates - Construction at the WWTP continues.
1 connection to the temporary septic tank.

Contract Operations;

Sturgeon – 6 Service Calls, 1 jetting call, 5 lift station calls.

Ashland – Routine O&M, Sludge processing has returned to normal.
Assisted with setting a repaired pump

Renick – Bi-monthly visits to check lift stations and reservoir

Hartsburg – Bi-weekly visits to check lift station and lagoon.