

Hillcreek Service Call Tracking

House/ Apartment #	Street Name	Date	Failure Type
950	Covered Bridge	12/2/2022	pump air locked
800	Covered Bridge	12/2/2022	replaced float switch
950	Covered Bridge	12/3/2022	pump air locked
800	Covered Bridge	12/3/2022	replaced pump
670	Logwood	12/8/2022	repaired float switch
7500	Cave Creek	12/17/2022	replaced float switch
950	Covered Bridge	12/19/2022	pump air locked
263	High Point Ln	12/24/2022	repaired float switch
7200	Chimney Ridge	1/1/2023	replaced float switches
851	Covered Bridge	1/9/2023	repaired float switch
620	Logwood	1/14/2023	repaired float switches
620	Logwood	1/15/2023	replaced float switches
851	Covered Bridge	1/27/2023	reset pump
851	Covered Bridge	1/28/2023	adjusted overloads