

Hillcreek Service Call Tracking

House/ Apartment #	Street Name	Date	Failure Type
720	Logwood Ln	10/1/2022	replace float switches
959	Covered Bridge	10/5/2022	reset pump
7502	Hillcreek	10/13/2022	repaired float switch
205	High Point Ln	10/29/2022	repaired service line
7500	Cave Creek	11/12/2022	repaired float switch
950	Covered Bridge	11/23/2022	reset pump
7500	Cave Creek	11/26/2022	replaced float switches
950	Covered Bridge	12/2/2022	pump air locked
800	Covered Bridge	12/2/2022	replaced float switch
950	Covered Bridge	12/3/2022	pump air locked
800	Covered Bridge	12/3/2022	replaced pump
670	Logwood	12/8/2022	repaired float switch
7500	Cave Creek	12/17/2022	replaced float switch
950	Covered Bridge	12/19/2022	pump air locked
263	High Point Ln	12/24/2022	repaired float switch
7200	Chimney Ridge	1/1/2023	replaced float switches
851	Covered Bridge	1/9/2023	repaired float switch
620	Logwood	1/14/2023	repaired float switches
620	Logwood	1/15/2023	replaced float switches
851	Covered Bridge	1/27/2023	reset pump
851	Covered Bridge	1/28/2023	adjusted overloads
263	High Point Ln	2/12/2023	replaced pump
7350	Chimney Ridge	2/14/2023	replaced float switch
7350	Chimney Ridge	2/16/2023	repaired float switch
7350	Chimney Ridge	2/17/2023	replaced float switch
7451	Chimney Ridge	2/23/2023	repaired float switches
7451	Chimney Ridge	2/25/2023	reset float switch controller