

## Hillcreek Service Call Tracking

House/ Apartment #	Street Name	Date	Failure Type
7200	Chimney Ridge	1/1/2023	replaced float switches
851	Covered Bridge	1/9/2023	repaired float switch
620	Logwood	1/14/2023	repaired float switches
620	Logwood	1/15/2023	replaced float switches
851	Covered Bridge	1/27/2023	reset pump
851	Covered Bridge	1/28/2023	adjusted overloads
263	High Point Ln	2/12/2023	replaced pump
7350	Chimney Ridge	2/14/2023	replaced float switch
7350	Chimney Ridge	2/16/2023	repaired float switch
7350	Chimney Ridge	2/17/2023	replaced float switch
7451	Chimney Ridge	2/23/2023	repaired float switches
7451	Chimney Ridge	2/25/2023	reset float switch controller
7451	Chimney Ridge	3/4/2023	replace float switches
501	Covered Bridge	3/7/2023	replace pump
263	High Point Ln	4/10/2023	replace pump
551	Covered Bridge	4/11/2023	repair internal piping
551	Covered Bridge	4/12/2023	replace pump
601	Logwood	4/13/2023	replace float switch
450	Covered Bridge	4/18/2023	clean ants out of control panel
561	Logwood	4/21/2023	replace pump
7601	Chimney Ridge	4/25/2023	replace float switch
1191	Covered Bridge	4/25/2023	repaired float switch
7611	Hillcreek	4/25/2023	replace float switch