

**Boone County Regional Sewer District
Operations and Maintenance Report
Virgil Farnen
October 2023**

Line Maintenance –2 pressure service line repairs.

540' of sewer main cctv'd

6-Month List completed, 13140' root sawed or jetted.

Pumps cleared – Debris removed from pump at Rocheport Trailside lift station.

Pressure Service Calls - 11	Hillcreek -	3	Woodlands -	5
	Kinkade -	1	County Downs -	2

Gravity Service Calls - 0 – Public, 1 - Private problems

Contract Service Calls – 3 1 each at Clark, Sturgeon and Ashland

MO One Calls – Received 331, Located 103

Sludge – 20000 gallons de-watered, and 32500 gallons hauled.

Connection Inspections – No inspections.

On Going and Planned Activities – Line maintenance, sludge processing and disposal. Right-of-Way clearing. CCTV Prairie Meadows service area.

New Construction –

Brookfield Estates WWTP – Construction continues. Working on punch list
Continues. Forcemain pressure test complete.
Approved clarifier anchors installed.

Trade Winds Plat 5 – 746' of 8" PVC sewer main and 5 manholes constructed.

Clark Service Call – Request from Mayor for jetting services. We responded and cleared a public main stoppage.

Contract Operations;

Sturgeon – Twice weekly visits to check lagoon and lift stations.

1 Service Call, unmapped public main stoppage.

Ashland – One full time employee assigned.

1 Service Call, public main stoppage.

Renick – Bi-weekly visits to check lift stations and reservoir. Irrigation continues.

Hartsburg – Twice weekly visits to check lift station and lagoon.