

Hillcreek Service Call Tracking

Street Name	Date	Failure Type
Chimney Ridge	9/3/2023	reset pump overload
Covered Bridge	9/4/2023	reset pump overload
Covered Bridge	9/5/2023	reset pump overload
Chimney Ridge	9/5/2023	reset pump overload
Covered Bridge	9/7/2023	plugged pump
Chimney Ridge	9/9/2023	bled air out of main
Hillcreek	9/10/2023	replaced pump
Hillcreek	10/3/2023	replaced float switch
Hillcreek	10/11/2023	replaced pump
Hillcreek	10/24/2023	replaced float switch