

## Hillcreek Service Call Tracking

House #	Street Name	Date	Failure Type
7300	Chimney Ridge	9/3/2023	reset pump overload
950	Covered Bridge	9/4/2023	reset pump overload
950	Covered Bridge	9/5/2023	reset pump overload
7300	Chimney Ridge	9/5/2023	reset pump overload
950	Covered Bridge	9/7/2023	plugged pump
7300	Chimney Ridge	9/9/2023	bled air out of main
7902	Hillcreek	9/10/2023	replaced pump
7731	Hillcreek	10/3/2023	replaced float switch
8071	Hillcreek	10/11/2023	replaced pump
1301	Hillcreek	10/24/2023	replaced float switch
950	Covered Bridge	11/6/2023	checked OK
1301	Covered Bridge	11/10/2023	replaced float switches
7502	Hillcreek	11/11/2023	replaced float switches
550	Covered Bridge	11/13/2023	repair piping outside of tank
7501	Cave Creek	11/16/2023	replaced float switches
501	Covered Bridge	11/19/2023	checked OK, adjusted floats
7802	Hillcreek	11/21/2023	replace float switch
7802	Hillcreek	11/23/2023	connect spare wires to float switch
501	Covered Bridge	11/24/2023	redid wire connections