

Hillcreek Service Call Tracking

House #	Street Name	Date	Failure Type	Labor Cost	Equip Cost
670	Logwood	12/5/2023	redid wire connections		
7431	Cave Creek	12/8/2023	replaced float switch		
7451	Chimney Ridge	12/10/2023	replaced float switch		
8181	Hillcreek	12/11/2023	no power to control panel		
7902	Hillcreek	12/13/2023	checked ok		
620	Logwood	12/21/2023	replaced pump		
7500	Cave Creek	12/23/2023	freplaced float switch + circuit brd		
7802	Hillcreek	12/26/2023	replaced pump		
7801	Cave Creek	12/26/2023	replaced circuit board		
7601	Cave Creek	12/30/2023	replaced check valve		
7431	Cave Creek	12/31/2023	reset pump		
7652	Hillcreek	12/31/2023	replaced float switch		
7702	Hillcreek	1/2/2024	repaired float switch		
7601	Chimney Ridge	1/3/2024	main repair		
7350	Chimney Ridge	1/5/2024	repair piping outside of tank		
7431	Cave Creek	1/11/2024	reset pump		
7431	Cave Creek	1/12/2024	replace pump		
1050	Covered Bridge	1/17/2024	reset pump		
7431	Cave Creek	1/17/2024	repipe to prevent air-locking		
263	High Point Ln	1/18/2024	replace float switch		
263	High Point Ln	1/23/2024	readjusted float switch		
263	High Point Ln	1/24/2024	air-lock, released air from mainline		
7501	Cave Creek	1/24/2024	reset pump		
7431	Cave Creek	1/28/2024	reoccurring air locking		
1101	Covered Bridge	1/28/2024	rewire pump connections		
1101	Covered Bridge	1/29/2024	replace float switch		