

Hillcreek Service Call Tracking

| House # | Street Name | Date | Failure Type | Labor Cost | Equip Cost |
|---------|----------------|------------|--------------------------------------|------------|------------|
| 670 | Logwood | 12/5/2023 | redid wire connections | | |
| 7431 | Cave Creek | 12/8/2023 | replaced float switch | | |
| 7451 | Chimney Ridge | 12/10/2023 | replaced float switch | | |
| 8181 | Hillcreek | 12/11/2023 | no power to control panel | | |
| 7902 | Hillcreek | 12/13/2023 | checked ok | | |
| 620 | Logwood | 12/21/2023 | replaced pump | | |
| 7500 | Cave Creek | 12/23/2023 | freplaced float switch + circuit brd | | |
| 7802 | Hillcreek | 12/26/2023 | replaced pump | | |
| 7801 | Cave Creek | 12/26/2023 | replaced circuit board | | |
| 7601 | Cave Creek | 12/30/2023 | replaced check valve | | |
| 7431 | Cave Creek | 12/31/2023 | reset pump | | |
| 7652 | Hillcreek | 12/31/2023 | replaced float switch | | |
| 7702 | Hillcreek | 1/2/2024 | repaired float switch | | |
| 7601 | Chimney Ridge | 1/3/2024 | main repair | | |
| 7350 | Chimney Ridge | 1/5/2024 | repair piping outside of tank | | |
| 7431 | Cave Creek | 1/11/2024 | reset pump | | |
| 7431 | Cave Creek | 1/12/2024 | replace pump | | |
| 1050 | Covered Bridge | 1/17/2024 | reset pump | | |
| 7431 | Cave Creek | 1/17/2024 | repipe to prevent air-locking | | |
| 263 | High Point Ln | 1/18/2024 | replace float switch | | |
| 263 | High Point Ln | 1/23/2024 | readjusted float switch | | |
| 263 | High Point Ln | 1/24/2024 | air-lock, released air from mainline | | |
| 7501 | Cave Creek | 1/24/2024 | reset pump | | |
| 7431 | Cave Creek | 1/28/2024 | reoccurring air locking | | |
| 1101 | Covered Bridge | 1/28/2024 | rewire pump connections | | |
| 1101 | Covered Bridge | 1/29/2024 | replace float switch | | |