

**Boone County Regional Sewer District
Operations and Maintenance Report
Virgil Farnen
February, 2024**

February – We were plagued with locate request from primarily trenchless excavators installing fiber optic systems. We received 530 requests, with an estimated 320 site visits. We physically marked 248 of the requests.

Line Maintenance – We did 3 pressure sewer main repairs and 2 pressure service line repairs. We jetted or root sawed 16,535’ of sewer main, and CCTV’d another 1228’.

Pumps pulled for service – Sturgeon and Rocheport to remove debris

Pressure Service Calls - 15	Hillcreek -	1	Woodlands -	2
	Heather Hills -	2	Brookfield -	2
	Richardson -	1	Kinkade -	2
	Oak Hills -	1	Lake Capri -	2
	Deerfield -	1	Arrowhead Lake -	1

Gravity Service Calls - 2 – Public, w/1 main blockage and 1 toilet eruption.
1 - Building backup, 2 - Private problems

Contract Service Calls – 2 @ Sturgeon

WWTP / LS Alarm Calls – 2 Cedar Gate WWTF
Sun Valley lift stations

MO One Calls – Received 530, Located 248

Sludge – 30000 gallons processed at S. Rt K and 10.7 Dry tons hauled from S Rt K and Rocky Fork

Connection Inspections – 12 inspection, which includes 5 Final inspections

On Going and Planned Activities – Line maintenance, sludge processing and disposal.

New Construction – Brookfield Estates WWTP – work on punch list items continue.

Contract Operations;

Sturgeon – Twice weekly visits to check lagoon and lift stations.

2 Service calls, 1 jetting and 1 lift station alarm.

Ashland – One District full time employee assigned.

Contract renewal proposed with 11% increase.

Ashland's "B" certified operator gave two weeks' notice on March 1st.

Renick – Bi-weekly visits to check lift stations and reservoir.

Hartsburg – Twice weekly visits to check lift station and lagoon.