

Hillcreek Service Call Tracking

House #	Street Name	Date	Failure Type
7702	Hillcreek	1/2/2024	repaired float switch
7601	Chimney Ridge	1/3/2024	main repair
7350	Chimney Ridge	1/5/2024	repair piping outside of tank
7431	Cave Creek	1/11/2024	reset pump
7431	Cave Creek	1/12/2024	replace pump
1050	Covered Bridge	1/17/2024	reset pump
7431	Cave Creek	1/17/2024	repipe to prevent air-locking
263	High Point Ln	1/18/2024	replace float switch
263	High Point Ln	1/23/2024	readjusted float switch
263	High Point Ln	1/24/2024	air-lock, released air from mainline
7501	Cave Creek	1/24/2024	reset pump
7431	Cave Creek	1/28/2024	reoccurring air locking
1101	Covered Bridge	1/28/2024	rewire pump connections
1101	Covered Bridge	1/29/2024	replace float switch
7301	Chimney Ridge	2/15/2024	repair piping outside of tank
551	Covered Bridge	3/5/2024	readjusted float switch