

Boone County Regional Sewer District
Operations and Maintenance Report
Virgil Farnen
April, 2024

Line Maintenance – We had 1 pressure service line repair. We cleaned 7010 ft of gravity sewer main. We CCTV'd 612 ft of sewer main.

Pumps pulled for service – Bonne Femme, and 2 visits to Sturgeon's Burks LS

Basement Back up – Breezewood Estates, 1 blockage, 2 basements flooded.

Pressure Service Calls - 25	Hillcreek -	6	Woodlands -	6
	County Downs	1	Heather Hills -	2
	Richardson -	3	Kinkade -	3
	Lake Capri -	2	Midway Arms -	1
	Shalimar-	1		

Gravity Service Calls - 2 – Public main line blockages.
9 - Private problem service calls.

MO DNR Inspections – Midway Crossing and Prairie Meadows were inspected.
Inspection reports received, facilities "Found in Compliance"

Contract Service Calls – 2 Sturgeon's, Burks Lift Station

WWTP / LS Alarm Calls – 2 South Route K, power outage.
Cedar Gate aerator not running.

MO One Calls – Received 470, Located 155

Sludge – 43200 gallons of sludge processed or hauled. We hauled 6.3 dry tons of sludge to the landfill.

Rocky Fork Flowmeter – There was a communication error between the flowmeter and the UV unit that was discovered and fixed when time allowed. Because of this the April flows are flat and inaccurate.

Connection Inspections – 14 inspection, all Final inspections

On Going and Planned Activities – Line maintenance, sludge processing and disposal.

New Construction – Brookfield Estates WWTP – work on punch list items cont.

Contract Operations;

Sturgeon – Twice weekly visits to check lagoon and lift stations.

2 Service calls

Contract renewal discussions have just begun. A 3.5% increase has been proposed.

Ashland – One full time employee assigned.

2 Year Operating Contract approved by Ashland City Council

Hartsburg – Twice weekly visits to check lift station and lagoon.

Operations Staff Update -

Entry level position, currently we have scheduled 8 interviews with only 3 candidates interviewed. We have offered the position to all three candidates and currently 2 have declined the offer.

Lead Operator position, we have interviewed both current employees that have applied for the position. We have attempted to interview a outside candidate with no response to date.

Wastewater/Equipment Operator was terminated.