

Exceedances for 1st Quarter 2024

Facility	Parameter	Limits		Reported Results	
		Weekly	Monthly	Weekly	Monthly

Highfield Acres	BOD	65	45	149	149
	TSS	120	80	580	580

A severe alga bloom occurred. Resampling would not have gotten the Monthly average below limits.

Midway Arms	BOD	45	30	51	22.7
	TSS	45	30	64	26.3

Found control timer operating sporadically mid-quarter. Repaired and resampled to get our Monthly average below limits.

Richardson Acres	TSS	110	70	98	98
	pH	Max 9.0		9.5	

There was a management change at the Lab & when we received the results form the lab it was to late to resample to achieve a monthly average within limits.

Rocky Fork	BOD	23	15	24	17.3
	% Removal BOD	> 85			75

The Operator believes there was a lab error because the sample was clear and odorless as usual. The composite sample for Influent BOD tested at 96 mg/l to calculate % removal.

