

**Boone County Regional Sewer District  
Operations and Maintenance Report  
Virgil Farnen  
May, 2024**

**Line Maintenance** – We had 3 pressure service line repairs. We cleaned 13140 ft of gravity sewer main, that included our 6-month list. We CCTV'd 325 ft of sewer main.

**Pumps pulled for service** – South Route K EQ Station, pulled a pump and replaced with new pump.

**District main blockage** – Cedar Lake Siphon

<b>Pressure Service Calls - 23</b>	Hillcreek -	7	Woodlands -	6
	County Downs	2	Heather Hills -	1
	Quarter Mile -	2	Kinkade -	2
	Brookfield -	2	Deerfield -	1

**Gravity Service Calls** - 1 – Public main line blockages.  
8 - Private problem service calls.

**MO DNR Inspections** – No Inspections to report

**Contract Service Calls** – 2 Sturgeon's, Burks Lift Station and CCTV a connection.

**WWTP / LS Alarm Calls** – 2 Midway Crossings audible alarm on generator.  
Lake of the Woods LS, high level alarm.

**MO One Calls** – Received 313, Located 87

**Sludge** – 101,000 gallons of sludge processed.

**Connection Inspections** – 14 inspection, 3 were Final inspections

**On Going and Planned Activities** – Line maintenance, sludge processing and disposal.

**New Construction** – Brookfield Estates WWTP – diverted flow to new treatment plant. We have been operating the TP, and forwarding our concerns to the contractor. The contractor(s) are addressing the discrepancies.

**Contract Operations;**

**Sturgeon** – Twice weekly visits to check lagoon and lift stations.

2 Service calls

Contract renewal discussions have just begun. A 3.5% increase has been proposed.

**Ashland** – One full time employee assigned.

2 Year Operating Contract approved by Ashland City Council

**Hartsburg** – Twice weekly visits to check lift station and lagoon.

**Operations Staff Update -**

We currently have 3 position open in operations.

1 Temp employee from Express Employment Professionals has onboarded and is helping with locates and maintenance task.

4 Employment offers have been made with none accepted.

Application are being accepted and interviews still scheduled.

Lead Operator position, we have interviewed both current employees that have applied for the position. We have postponed the promotion until we can evaluate the employee performing the new responsibilities.