

**Boone County Regional Sewer District
Operations and Maintenance Report
Jason Horton
March 2025**

Line Maintenance –

- 800 ft during service calls
- Camera 200 ft Spring Park

District main blockage – 5900 Spring Court jetted line to clear blockage. Found main line had an offset due to fernco connection separation from main. Dug up and repaired main. Advised homeowner regarding sewer districts back-up policy and currently working with homeowner.

Pumps pulled for service – Received rebuilt pump for Rocky Fork Influent L.S. Had to send back because cord was 11ft short. Independent electric picked the pump back up to put longer cords on it.

Pressure Service Calls - 15	Woodland - -3	Hill creek -4
	Brookfield - -1	Creasy Springs -0
	Fall Creek -1	Lake Capri -2
	Heather Hills -3	Arrowhead Lake Estates - 1

Private Gravity Service Calls - 4- Private problem service calls.

Contract Service Calls -3

WWTP / Lift Station Alarm Calls – 0

MO DNR Inspections – 1 City of Sturgeon

MO One Calls – Received 601, Located 455

Sludge – Processed sludge at Rocky Fork into bags. Have not hauled to the land fill yet.

NPDES Permits – We currently have 3 Expired NPDES Permits.

American Outdoor Brands, Eagle Knoll and Twin Lakes.

Ashland and Hartsburg are also expired.

On Going and Planned Activities – Haul and process sludge at Rocky Fork, St Rt K, Rocheport. Routine line maintenance, Obtaining CDL Licenses, Operator Training. Install new control panel for Sturgeon at South Ogden lift station.

New Construction – Rollingwood Lift Station complete, Hinton Road Higbee Lake Force Main Complete

Contract Operations;

Sturgeon – Three visits to check lagoon and lift stations.

Have ordered a new pump and control panel for the South lift station. New control panel for S. Ogden lift station has arrived.

Ashland – One employee assigned full time.

Hartsburg – Twice weekly visits to check lift station and lagoon monitoring.