

**Boone County Regional Sewer District
Operations and Maintenance Report
Jason Horton
July 2025**

Line Maintenance –

2236 ft Root saw SL Rat 12,558 ft
2236 camera work

District main blockage – 0

Pumps pulled for service – El Rey has been taken to Vandeventer for repair due to seal failure

Pressure Service Calls - 26	Woodlands - 7	Hill creek -10
	Lake Capri - 2	Brookfield - 2
	Sunrise Estates-	Deerfield -1
	El Rey-1	Brown Station - 2
	Sheridan Hills - 1	

Private Gravity Service Calls - 1 - Private problem service calls.

Contract Service Calls - 0

WWTP / Lift Station Alarm Calls – 2 Bonne Femme Lift station alternator issues

MO DNR Inspections – 0

MO One Calls – Received 595, Located 499

Sludge – 0 gallons liquid hauled from Rocky Fork Digester. We did process some into bags at Rocky Fork

NPDES Permits – We currently have 3 Expired NPDES Permits.

American Outdoor Brands, Eagle Knoll and Twin Lakes.
Ashland and Hartsburg are also expired.

On Going and Planned Activities – Haul and process sludge. Routine line maintenance, SL Rat, CDL Licenses, Operator Training. 1 left to driver's test. Scheduled for 8/19 8/20. Continue Osha 10 training. 2 have completed the course.

New Construction – Sewer Extension on Wagon trail rd.

Contract Operations;

Ashland – One employee assigned full time.

Hartsburg – Twice weekly visits to check lift station and lagoon monitoring.

BOONE COUNTY REGIONAL SEWER DISTRICT - SEWER MAINTENANCE SUMMARY

FISCAL YEAR 2025	Service Calls					Sewer Maintenance Activities & Quantities															
	District Gravity Main Calls	WRF & PUMP STATION ALARM	Private Problem Service Calls	CONTRACT & emergency locates	Pressure Service Calls	TOTAL LABOR / MATERIALS COST	AVERAGE COST / CALL	STEP PUMP REPLACEMENT	GRINDER PUMP REPLACEMENT	SEWER MAIN CLEANED BY FLUSHING and root saw	CCTV INSPECTION	SL RAT FOOTAGE	Pressure Sewer Repairs	Sewer Main replacement-footage	Sewer Main - New Construction including force main	CIPP Projects completed -footage	MANHOLE ADJUSTED or REPAIRED	MANHOLES RELINED and NEW MANHOLE CONSTRUCTION	Dry Tons of Sludge Disposed	Gallons of Sludge Processed or Disposed	ONE CALL LOCATES - Received/Performed
JANUARY	5	1	7	1	24	\$14,907	\$403	6	2	15,000	0		0	0	0	0	0	0	7	0	246/84
FEBRUARY	10	1	9	1	16	\$6,984	\$436	0	3	0	350		0	0	1,525	0	0	0	0	0	269/85
MARCH	7	0	4	0	13	\$11,329	\$472	3	1	800	60		1	0	0	0	0	0	0	5,000	601/455
APRIL	2	3	4	0	9	\$7,142	\$397	1	1	0	0		0	0	920	0	0	0	0.19	10,000	463/383
MAY	3	2	6	0	19	\$13,724	\$722	4	2	8,642	489		1	11	0	0	2	0	0	75,000	617/522
JUNE	4	3	4	0	32	\$17,409	\$415	5	8	4,877	0		2	6	0	0	0	0	29	60,000	609/541
JULY	1	2	2	0	26	\$20,873	\$803	7	4	2,238	2,238	12,558	1	0	317	0	0	0	0	0	595/499
AUGUST																					
SEPTEMBER																					
OCTOBER																					
NOVEMBER																					
DECEMBER																					
TOTAL																					
Monthly Avg																					