

**Boone County Regional Sewer District  
Operations and Maintenance Report  
Jason Horton  
August 2025**

**Line Maintenance –**

340 ft Root saw              SL Rat 20,067 ft  
Uncovered 3 buried manholes

**District main blockage – 0**

**Pumps pulled for service –** El Rey pump returned and installed back into service  
09/08/2025

<b>Pressure Service Calls - 18</b>	Woodlands - 6	Hill creek - 4
	Deerfield - 2	Brookfield - 1
	Boli- 1	Lake Capri - 1
	Brown Station - 1	Kinkade - 2

**Private Gravity Service Calls - 1** - Private problem service calls.

**Contract Service Calls - 1**

**WWTP / Lift Station Alarm Calls – 0**

**MO DNR Inspections – 0**

**MO One Calls –** Received 520, Located 461

**Sludge –** 5,000 gallons liquid hauled from Eagle Knoll & St Rt K . We also processed some into bags at Rocky Fork

**NPDES Permits –** We currently have 3 Expired NPDES Permits.

American Outdoor Brands, Eagle Knoll and Twin Lakes.  
Hartsburg has now been renewed. Ashland is still expired and will likely remain so until the new plant is put into service.

**On Going and Planned Activities** – Haul and process sludge. Routine line maintenance, SL Rat, Operator License Training. Continue Osha 10 training. 2 have completed the course. 2 employees going to Pipeline assessment certification training September 22-25.

**New Construction – None to report**

**Contract Operations;**

**Ashland** – One employee assigned full time. May be assigning more than one with Ashland being short handed on employees.

**Hartsburg** – Twice weekly visits to check lift station and lagoon monitoring.

BOONE COUNTY REGIONAL SEWER DISTRICT - SEWER MAINTENANCE SUMMARY

FISCAL YEAR 2025	Service Calls					Sewer Maintenance Activities & Quantities															
	District Gravity Main Calls	WRF & PUMP STATION ALARM	Private Problem Service Calls	CONTRACT & emergency locates	Pressure Service Calls	TOTAL LABOR / MATERIALS COST	AVERAGE COST / CALL	STEP PUMP REPLACEMENT	GRINDER PUMP REPLACEMENT	SEWER MAIN CLEANED BY FLUSHING and root saw	CCTV INSPECTION	SL RAT FOOTAGE	Pressure Sewer Repairs	Sewer Main replacement-footage	Sewer Main - New Construction including force main	CIPP Projects completed -footage	MANHOLE ADJUSTED or REPAIRED	MANHOLES RELINED and NEW MANHOLE CONSTRUCTION	Dry Tons of Sludge Disposed	Gallons of Sludge Processed or Disposed	ONE CALL LOCATES - Received/Performed
JANUARY	5	1	7	1	24	\$14,907	\$403	6	2	15,000	0		0	0	0	0	0	0	7	0	246/84
FEBRUARY	10	1	9	1	16	\$6,984	\$436	0	3	0	350		0	0	1,525	0	0	0	0	0	269/85
MARCH	7	0	4	0	13	\$11,329	\$472	3	1	800	60		1	0	0	0	0	0	0	5,000	601/455
APRIL	2	3	4	0	9	\$7,142	\$397	1	1	0	0		0	0	920	0	0	0	0.19	10,000	463/383
MAY	3	2	6	0	19	\$13,724	\$722	4	2	8,642	489		1	11	0	0	2	0	0	75,000	617/522
JUNE	4	3	4	0	32	\$17,409	\$415	5	8	4,877	0		2	6	0	0	0	0	29	60,000	609/541
JULY	1	2	2	0	26	\$20,873	\$803	7	4	2,238	2,238	12,558	1	0	317	0	0	0	0	0	595/499
AUGUST	0	0	1	0	18	\$10,226	\$568	5	3	340	0	20,067	0	0	0	0	0	0	12	5,000	520/461
SEPTEMBER																					
OCTOBER																					
NOVEMBER																					
DECEMBER																					
TOTAL																					
Monthly Avg																					