



ADDENDUM NO. 2

DATE: November 12, 2025

PROJECT: Lift Station Upgrades (Rocheport Trailside Lift Station)
Boone County Regional Sewer District

SUBJECT: Addendum No. 2
Cochran Project No. 25-10224
BCRSD Project #09-2025

This Addendum forms a part of the Bidding and Contract Documents and modifies the original Bidding Documents.
FAILURE TO ACKNOWLEDGE RECEIPT OF ADDENDUM MAY SUBJECT BIDDER TO DISQUALIFICATION.

GENERAL:

1. The existing stairs to the existing platform may be unbolted and stored by the contractor if needed to perform concrete work around the platform. BCRSD crews will assist, if requested, and can store the stairs off-site if needed.
2. Any additional portions of the fence needed to be removed by the contractor to complete the work should be bid as follows: 1) Any demolition work should be incidental to the base bid. 2) Any new fencing required to be re-installed will be paid at the unit rate described in Base Bid Item #5 "8' tall wood fencing"
3. The existing pumps in the wet well are Barnes 4SE4524L .
4. If contractors' pollution liability policy limits plus their umbrella liability coverage exceeds \$3,448,710, then there shall be no requirement to produce additional or supplemental pollution liability coverage as discussed on page SC-7 of the specifications.
5. The contractor is not providing professional design services for this project and professional liability insurance is not required though it is discussed on page SC-7 of the specifications.
6. The exact dimensions of the top of the casting between existing precast barrels and existing precast lids on the lift stations is unknown but believed to not be smooth or flat. The contractor may sawcut a smooth joint if the existing joint is irregular or not capable of being replicated with the extension barrel. Alternatively, the contractor may remove the lid and coordinate the exact dimensions with the precast concrete provider to avoid saw cutting the top of the existing barrel. The contractor shall determine their means and methods for this task and include in the bid.

END ADDENDUM NO. 2