

BOONE COUNTY REGIONAL SEWER DISTRICT - SEWER MAINTENANCE SUMMARY

	Service Calls							Sewer Maintenance Activities & Quantities															One Calls	
	District Gravity Main Calls	WWTF & PUMP STATION ALARM	PRIVATE PROBLEM SERVICE CALLS	CONTRACT & EMERGENCY LOCATES	PRESSURE SERVICE CALLS	TOTAL PRESSURE LABOR / MATERIALS COST	AVERAGE PRESSURE COST / CALL	STEP PUMP REPLACEMENT	GRINDER PUMP REPLACEMENT	SEWER MAIN CLEANED BY FLUSHING AND ROOT SAW, LF	CCTV INSPECTION, LF	SL RAT FOOTAGE	Percent of SL Rat that required Jetting	Percent of Gravity System Maintenance completed	Pressure Sewer Repairs	Sewer Main replacement-footage	Sewer Main - New Construction including force main	CIPP Projects completed -footage	MANHOLE ADJUSTED or REPAIRED	MANHOLES RELINED and NEW MANHOLE CONSTRUCTION	Dry Tons of Sludge Disposed	Gallons of Sludge Processed or Disposed	ONE CALL LOCATES - Received	ONE CALL LOCATES -Performed
FISCAL YEAR 2026																								
JANUARY	0	0	2	0	16	\$7,645	\$478	0	2	5,392	3,166	55,001	11%	9%	2	0	0	0	0	0	0	5,000	318	152
FEBRUARY	1	1	3	0	4	\$1,948	\$487	0	1	5,002	2,828	28,673	21%	4%	1	87	273	0	0	2	0	65,000	372	339
MARCH	2	0	1	0	15	\$9,423	\$628	1	4	4,085	1,466	19,370	27%	3%	1	0	0	0	0	0	0	79,600	457	432
APRIL	3	2	2	0	19	\$13,474	\$709	3	3	2,896	1,933	42,831	7%	7%	4	0	0	0	0	0	103.29	92,500	451	437
MAY	0	2	1	0	16	\$9,824	\$614	2	2	26,456	1,767	13,592	16%	5%	0	6	0	0	2	0	0	5,000	423	396
JUNE	0	1	0	0	25	\$13,106	\$524	3	2	24,026	2,736	472	2%	4%	0	10	0	0	0	0	0	2,500	326	314
JULY	0	0	1	0	14	\$7,578	\$541	3	1	3,240	7,294	0	0	2%	2	20	0	0	0	0	0	5,000	374	353
AUGUST																								
SEPTEMBER																								
OCTOBER																								
NOVEMBER																								
DECEMBER																								
TOTAL	6	6	10	0	109	\$62,998	\$578	12	15	71,097	21,190	159,939			10	123	273	0	2	2	103	254,600	2,021	2,423
AVERAGE	1	1	1	0	16	\$9,000	\$569	2	2	10,157	3,027	22,848	0	0	1	18	39	0	0	0	15	36,371	404	346

**Boone County Regional Sewer District
Operations and Maintenance Report
Jason Horton
July 2026**

Line Maintenance

SL Rat –
Root Saw/Jetting 3,240 ft
CCTV- 7,294

District main blockage – 0

Pumps pulled for service – Green Hills, Nursery Heights, Fairway West, Rollingwood Prairie Meadows

Pressure Service Calls – 13 Woodlands - 5
Kinkade Crossing - 3
Heather Hills - 2
Clear Creek – 1
Lake Capri - 2

Private Gravity Service Calls – 2

Contract Service Calls – 0

WWTP / Lift Station Alarm Calls – Prairie Meadows check valve failure and pump clogged, Hillview Check Valve Failure and pumps clogged, Fairway West Impellers worn out not pumping and check valves clogged

MO DNR Inspections – 0

MO One Calls – Received 374, Located 353

Sludge Processed/Hauled – 5,000 gallons hauled

On Going and Planned Activities – Haul and process sludge. Keep Line Maintenance caught up, Replace 80 ft of clay tile with ductile iron pipe in Lakeland Acres. Repair line at El Chaparral that has large void in pipe.

Upcoming Training – Confined space and trench safety classes. Caleb and Seth will be attending a Advanced Electrical Class in September

New Construction – Willow Creek East, Clearview Heights